



NAPA SANITATION DISTRICT MEMORANDUM

DATE: June 9, 2026
TO: LCWD Board of Directors
FROM: Andrew Damron, NapaSan
SUBJECT: Recycled Water Update

Purpose

Update the LCWD Board on the status of the recycled water connections, usage, and recycled water quality data.

<u>Description</u>	<u>2016</u>	<u>2017</u>	<u>2018</u>	<u>2019</u>	<u>2020</u>	<u>2021</u>	<u>2022</u>	<u>2023</u>	<u>2024</u>	<u>2025</u>	<u>2026</u>
Summer Water Use (AF) (May – Oct)	110	194	239	210	436	819	591	371	446	321	
Calendar Year Actual Water Use (AF)	122	197	319	274	636	1,147	824	383	460	325	36*
Connected Parcels (out of 107)											75 (70%)
Connected Acres (out of 4,128)											3,042 (74%)
Peak Hour Flow (GPM) **			2,400	2,425	3,260	3,211	4,150	2,700	3,900	3,400	
Peak Day Flow (GPM) **			1,950	2,200	2,680	2,760	2,400	1,900	2,600	1,900	

* 2026 data through April 30, 2026

** Approximately 3,500 GPM design capacity (peak day in 2025 was 7/10; peak hour 11am on 7/17)

Water Quality Data


The last Chloride sample was taken on 04/01/26 – Chloride Reading (mg/L)	128
--	-----

NapaSan Contacts

For questions related to permitting including plan review, inspection	Gavin Glascott	707-258-6012	gglascott@napasan.com
For questions on recycled water service and pressure issues	Kyle Tahsler	707-312-1609	ktahsler@napasan.com
For a construction related question or to schedule an inspection	Brad Cagle	707-312-1761	bcagle@napasan.com
For questions related to recycled water quality	Chris Francis	707-258-6081	cfrancis@napasan.com
For questions on billing	Donell Mannor	707-258-6032	dmannor@napasan.com

Chloride Chart

Go to www.napasan.com for updates.



LCWD Connected Parcels as of June 9, 2026

